


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.04V I:0.2236A P:24.182W PF:0.9011 Freq:60.00Hz Lamp Flux:948.949x1 lm		
NAME: FR-W1802-38L	TYPE:Fan Control	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 39.24 lm/W			
MODEL		Imax(cd)	300.3	S/MH(C0/180)	1.26
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	1.28
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	948.95	η UP,DN(C0-180)	1.8,47.8
NOMINAL FLUX(lm)	948.949	CIE CLASS	DIRECT	η UP,DN(C180-360)	1.9,48.5
LAMPS INSIDE	1	η up(%)	3.7	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	120	η down(%)	96.3	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM


ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	$\%lum, lamp$
10	294.5	294.8	294.0	293.2	293.5	295.1	296.1	295.7	0- 10	28.36	28.36	2.99,2.99
20	279.9	278.8	277.9	277.2	277.9	279.5	281.7	281.9	10- 20	81.34	109.7	11.6,11.6
30	255.7	254.7	253.0	251.7	253.4	256.0	258.3	259.1	20- 30	123.7	233.4	24.6,24.6
40	223.4	221.8	220.2	218.6	220.3	223.0	225.7	226.8	30- 40	150.0	383.4	40.4,40.4
50	185.0	183.4	180.9	179.1	181.0	183.9	187.2	188.1	40- 50	157.1	540.5	57,57
60	142.0	140.3	138.1	136.0	137.7	140.2	143.5	145.1	50- 60	145.1	685.6	72.2,72.2
70	98.23	97.12	94.98	92.83	92.96	94.85	98.03	99.83	60- 70	117.1	802.6	84.6,84.6
80	53.78	53.45	51.93	49.59	49.14	49.95	52.59	54.55	70- 80	77.91	880.5	92.8,92.8
90	13.74	13.98	13.86	13.34	11.99	11.74	13.39	14.28	80- 90	33.57	914.1	96.3,96.3
100	9.256	9.176	9.437	8.895	8.192	8.283	9.843	10.39	90-100	11.86	925.9	97.6,97.6
110	6.774	6.531	6.789	6.392	5.885	6.224	7.541	7.816	100-110	8.366	934.3	98.5,98.5
120	4.965	4.653	4.804	4.543	4.266	4.576	5.654	5.776	110-120	5.743	940.1	99.1,99.1
130	3.466	3.356	3.202	3.042	3.182	3.075	3.969	4.343	120-130	3.711	943.8	99.5,99.5
140	2.230	2.245	1.952	1.829	2.641	1.916	2.778	3.129	130-140	2.175	945.9	99.7,99.7
150	1.465	1.824	1.645	1.796	2.341	1.750	2.208	1.934	140-150	1.256	947.2	99.8,99.8
160	1.626	1.657	2.186	2.485	2.580	2.544	2.299	1.562	150-160	0.9481	948.1	99.9,99.9
170	1.983	1.597	1.748	2.588	2.561	2.537	2.090	1.645	160-170	0.6360	948.8	100,100
180	0.5314	0.4611	1.429	1.463	0.5773	0.5581	1.331	0.5763	170-180	0.1697	948.9	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 γ Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES




LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	3706	3533
80	3099	2990
75	2937	2824
70	2874	2776
65	2842	2761
60	2842	2761
55	2866	2787
50	2881	2814
45	2914	2843

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-09-03

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.459m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.18	1.18	1.18	1.15	1.15	1.15	1.09	1.09	1.09	1.04	1.04	1.04	.99	.99	.99	.96
1.0	1.02	.97	.93	.99	.95	.91	.94	.91	.87	.90	.87	.84	.85	.83	.81	.79
2.0	.88	.81	.75	.86	.79	.74	.82	.76	.71	.78	.73	.69	.74	.70	.67	.65
3.0	.77	.68	.62	.75	.67	.61	.72	.65	.59	.68	.63	.58	.65	.60	.56	.54
4.0	.68	.59	.52	.66	.58	.51	.63	.56	.50	.61	.54	.49	.58	.53	.48	.46
5.0	.61	.51	.45	.59	.51	.44	.57	.49	.43	.54	.48	.42	.52	.46	.42	.39
6.0	.54	.45	.39	.53	.45	.38	.51	.43	.38	.49	.42	.37	.47	.41	.36	.34
7.0	.49	.40	.34	.48	.40	.34	.46	.39	.33	.45	.38	.33	.43	.37	.32	.30
8.0	.45	.36	.30	.44	.36	.30	.42	.35	.30	.41	.34	.29	.39	.33	.29	.27
9.0	.41	.33	.27	.40	.32	.27	.39	.32	.27	.38	.31	.26	.36	.30	.26	.24
10.0	.38	.30	.25	.37	.30	.24	.36	.29	.24	.35	.28	.24	.34	.28	.24	.22



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.335	.190	.060	.326	.186	.059	.311	.178	.057	.297	.171	.055	.284	.164	.053	
2.0	.306	.168	.052	.299	.165	.051	.285	.159	.049	.273	.153	.048	.261	.148	.047	
3.0	.280	.149	.045	.273	.146	.044	.261	.141	.043	.250	.137	.042	.239	.132	.041	
4.0	.256	.133	.039	.250	.131	.039	.239	.127	.038	.229	.123	.037	.220	.119	.036	
5.0	.235	.120	.035	.230	.118	.034	.220	.115	.034	.211	.111	.033	.203	.108	.033	
6.0	.217	.109	.031	.213	.107	.031	.204	.104	.030	.196	.102	.030	.188	.099	.029	
7.0	.202	.100	.028	.197	.098	.028	.189	.096	.028	.182	.093	.027	.175	.091	.027	
8.0	.188	.092	.026	.184	.091	.026	.177	.088	.025	.170	.086	.025	.164	.084	.025	
9.0	.176	.085	.024	.172	.084	.024	.166	.082	.023	.160	.080	.023	.154	.078	.023	
10.0	.165	.079	.022	.162	.078	.022	.156	.076	.022	.150	.075	.021	.145	.073	.021	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.218	.218	.218	.187	.187	.187	.127	.127	.127	.073	.073	.073	.023	.023	.023	
1.0	.210	.184	.161	.180	.158	.138	.123	.109	.096	.071	.063	.056	.023	.020	.018	
2.0	.203	.160	.125	.174	.138	.108	.119	.095	.075	.069	.056	.044	.022	.018	.014	
3.0	.195	.143	.101	.167	.123	.088	.115	.086	.062	.066	.050	.036	.021	.016	.012	
4.0	.187	.130	.086	.161	.112	.075	.110	.078	.053	.064	.046	.031	.021	.015	.010	
5.0	.180	.120	.075	.154	.103	.065	.106	.072	.046	.062	.042	.027	.020	.014	.009	
6.0	.172	.111	.067	.148	.096	.059	.102	.067	.042	.059	.040	.025	.019	.013	.008	
7.0	.165	.104	.062	.142	.091	.054	.098	.063	.038	.057	.037	.023	.018	.012	.008	
8.0	.159	.099	.057	.137	.086	.050	.095	.060	.036	.055	.035	.021	.018	.012	.007	
9.0	.153	.094	.054	.132	.081	.047	.091	.057	.033	.053	.034	.020	.017	.011	.007	
10.0	.147	.090	.051	.127	.078	.045	.088	.055	.032	.051	.032	.019	.017	.011	.006	

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	16.5	18.0	16.8	18.3	18.5	16.4	17.9	16.7	18.1	18.4
3H	18.3	19.7	18.6	20.0	20.3	18.1	19.5	18.5	19.8	20.1
4H	19.1	20.4	19.5	20.7	21.1	18.9	20.3	19.3	20.6	20.9
6H	19.8	21.1	20.2	21.4	21.8	19.7	20.9	20.0	21.3	21.6
8H	20.1	21.4	20.5	21.7	22.1	20.0	21.2	20.4	21.5	21.9
12H	20.4	21.6	20.8	22.0	22.3	20.2	21.4	20.7	21.8	22.2
4H 2H	17.1	18.5	17.5	18.8	19.1	17.0	18.4	17.4	18.7	19.0
3H	19.1	20.3	19.5	20.7	21.0	19.0	20.2	19.4	20.5	20.9
4H	20.1	21.2	20.5	21.6	22.0	20.0	21.0	20.4	21.4	21.8
6H	21.0	21.9	21.5	22.4	22.8	20.9	21.8	21.3	22.2	22.7
8H	21.4	22.3	21.9	22.7	23.2	21.2	22.1	21.7	22.6	23.0
12H	21.8	22.6	22.2	23.0	23.5	21.6	22.4	22.1	22.9	23.4
8H 4H	20.5	21.4	20.9	21.8	22.3	20.4	21.2	20.8	21.7	22.1
6H	21.6	22.3	22.1	22.8	23.3	21.4	22.2	21.9	22.7	23.2
8H	22.1	22.8	22.6	23.3	23.8	22.0	22.6	22.5	23.1	23.7
12H	22.6	23.2	23.1	23.7	24.3	22.5	23.0	23.0	23.6	24.1
12H 4H	20.5	21.3	21.0	21.8	22.3	20.4	21.2	20.9	21.7	22.2
6H	21.7	22.3	22.2	22.8	23.4	21.6	22.2	22.1	22.7	23.3
8H	22.3	22.9	22.8	23.4	23.9	22.2	22.7	22.7	23.2	23.8
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.2					+ 0.1 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H	+ 0.1 / - 0.3					+ 0.1 / - 0.3				

CIE Pub.117, 948.9 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = -0.2$)

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:


UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	55	43	36	54	43	36	53	42	36	29
0.80	65	53	45	64	52	45	62	51	44	37
1.00	73	61	54	72	61	53	69	62	53	45
1.25	80	69	61	78	68	61	75	66	60	52
1.50	85	75	67	83	74	66	80	71	65	57
2.00	92	83	76	90	81	75	86	79	73	64
2.50	96	88	81	94	86	80	89	83	78	69
3.00	100	92	86	97	90	85	93	87	82	73
4.00	104	98	92	101	96	91	96	92	88	78
5.00	106	101	97	104	99	95	99	95	91	81
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended				SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.459m [K=1.0000]
Remarks:

AAI CURVES




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:120.04V I:0.2236A P:24.182W PF:0.9011 Freq:60.00Hz Lamp Flux:948.949x1 lm		
NAME: FR-W1802-38L	TYPE:Fan Control	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	2787
L_0~180(75)av	2836
L_0~180(85)av	3444
L_90~270(65)av	2808
L_90~270(75)av	2864
L_90~270(85)av	3519
L_45(65)av	2802
L_45(75)av	2849
L_45(85)av	3480

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.459m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

C(DEG) γ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	299	299	299	299	299	299	299	299	299	299	299	299	299	299	299	299			
5	299	298	298	299	298	298	299	298	298	298	299	299	299	298	299	298			
10	294	295	295	294	294	293	293	293	293	294	295	295	296	295	296	296			
15	289	288	288	288	287	286	287	286	288	287	288	290	290	290	291	290			
20	280	280	279	278	278	277	277	277	278	279	280	281	282	281	282	282			
25	270	269	267	268	266	265	266	265	267	267	268	270	271	271	272	271			
30	256	255	255	253	253	251	252	252	253	254	256	257	258	258	259	258			
35	241	240	239	238	237	235	236	236	238	238	240	242	243	244	244	243			
40	223	223	222	221	220	218	219	218	220	222	223	224	226	226	227	227			
45	206	204	203	202	201	199	200	199	202	202	204	206	207	207	209	208			
50	185	184	183	182	181	179	179	178	181	182	184	185	187	187	188	188			
55	164	163	162	161	160	158	158	157	160	160	162	164	166	166	168	167			
60	142	141	140	139	138	137	136	135	138	139	140	142	144	144	145	145			
65	120	119	118	118	117	115	115	114	116	116	118	119	121	122	123	122			
70	98.2	97.8	97.1	96.2	95.0	93.5	92.8	91.7	93.0	93.5	94.8	96.4	98.0	98.9	99.8	99.9			
75	75.9	75.4	74.7	74.4	73.1	71.6	70.9	69.8	70.9	70.9	72.2	73.8	75.1	76.2	77.1	77.4			
80	53.8	53.8	53.4	52.9	51.9	50.6	49.6	48.4	49.1	49.2	49.9	51.2	52.6	53.7	54.6	55.0			
85	32.3	32.3	32.1	31.8	30.8	29.4	28.4	27.1	27.8	27.6	28.2	29.3	30.5	31.6	32.7	33.2			
90	13.7	13.7	14.0	14.1	13.9	13.4	13.3	12.4	12.0	11.7	11.7	12.5	13.4	14.0	14.3	14.3			
95	10.9	10.6	10.9	11.3	11.3	11.0	10.6	10.1	9.73	9.48	9.57	10.3	11.1	11.6	11.7	11.4			
100	9.26	8.98	9.18	9.40	9.44	9.23	8.90	8.43	8.19	8.11	8.28	8.94	9.84	10.4	10.4	9.94			
105	7.93	7.65	7.73	7.96	8.02	7.83	7.55	7.14	6.96	6.93	7.18	7.82	8.58	9.02	9.05	8.53			
110	6.77	6.48	6.53	6.70	6.79	6.65	6.39	6.02	5.88	5.95	6.22	6.87	7.54	7.81	7.82	7.36			
115	5.82	5.50	5.47	5.61	5.69	5.61	5.40	5.08	4.99	5.10	5.38	5.99	6.56	6.73	6.73	6.36			
120	4.96	4.63	4.65	4.66	4.80	4.73	4.54	4.27	4.27	4.34	4.58	5.14	5.65	5.72	5.78	5.49			
125	4.20	3.88	3.90	3.86	3.98	3.90	3.76	3.61	3.67	3.61	3.80	4.31	4.77	4.78	4.95	4.68			
130	3.47	3.18	3.36	3.19	3.20	3.14	3.04	3.01	3.18	3.01	3.08	3.52	3.97	3.98	4.34	3.92			
135	2.81	2.53	2.57	2.57	2.37	2.43	2.33	2.67	2.83	2.54	2.43	2.76	3.02	3.41	3.56	3.23			
140	2.23	2.00	2.24	2.03	1.95	1.87	1.83	2.36	2.64	2.26	1.92	2.07	2.78	2.82	3.13	2.62			
145	1.75	1.70	1.70	1.58	1.64	1.57	1.90	2.25	2.40	2.17	1.64	1.78	2.14	2.51	2.31	2.08			
150	1.47	1.63	1.82	1.72	1.65	1.64	1.80	2.34	2.34	2.30	1.75	1.79	2.21	1.96	1.93	1.73			
155	1.52	1.82	1.85	1.74	1.97	1.96	2.57	2.45	2.48	2.47	2.35	2.08	2.17	1.90	1.68	1.99			
160	1.63	1.42	1.66	1.69	2.19	2.22	2.48	2.93	2.58	2.60	2.54	2.26	2.30	2.47	1.56	2.06			
165	1.31	2.08	1.96	1.71	2.75	2.46	2.79	2.93	2.63	2.61	3.05	2.70	2.41	2.34	1.62	2.14			
170	1.98	1.65	1.60	1.65	1.75	1.68	2.59	2.57	2.56	2.56	2.54	2.68	2.09	1.68	1.64	1.64			
175	0.54	0.54	1.63	1.65	1.50	1.52	1.60	2.55	2.54	2.54	2.53	1.43	1.43	1.47	1.62	1.60			
180	0.53	0.53	0.46	1.42	1.43	1.45	1.46	0.86	0.58	0.52	0.56	1.32	1.33	0.97	0.58	0.51			

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-09-03

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks: